

1. Is there a preferred section size for the sheet pile? Or will any section that meets the minimum requirements be accepted?

Answer: Any z-shape section that meets the minimum section properties specified is acceptable. Shear area is likely to control.

2. Will it be acceptable to fabricate the handrail for the pile cap off site in sections and install on-site? If yes, then what would be the minimum distance between adjacent sections?

Answer: Yes, sections are acceptable. There is no current requirement for minimum length of sections.

3. Could you please clarify if it is acceptable for sheetpile to be coated from the factory, or if coating is required to be completed on site? If it is to be completed on site, is only the exposed portion of the sheetpile required to be coated?

Answer: Either painting after installing or in the shop is acceptable.

4. Could you please clarify the preferred coating? (epoxy, tar etc)

Answer: See note 8 on sheet CG211 and CG212.

5. Can you please clarify if limestone is an acceptable material for use as riprap, spalls, and bedding for this project?

Answer: Yes, as long as the limestone meets the various specified requirements.